



DIAMETERS

- 1.00in/25mm
- 1.50in/38mm
- 2.00in/51mm
- 2.50in/64mm
- 3.00in/76mm

MERTEX
WAYOUT®

Designed to improve life safety in the Fire Service.

- » Directional Arrows (patented) are engraved into and below the surface of the female coupling pointing in the direction of the water source with standard connectivity. Available in sizes 1 to 3 inch (25 to 76mm)
 - The visibility of the recessed arrows are enhanced by the addition of a highly reflective material
 - Arrows reflect under low lighting to assist in guiding the way out
 - Recessing the Arrow helps prevent damage to the reflective material from abrasion during use
 - The reflective Arrow greatly improves nighttime visibility of the hose line on the fire ground reducing accidental damage
- » Features the Identify® recessed area for color coding, bar coding and/or identification markings in sizes 1.5 to 3 inch (38 to 76mm)
- » Two Year All Hazards Warranty and 10 years against manufacturing defects
- » Available with the following fire hose products:
 - KRAKENEXO®
 - CARRY-LITE®
 - HYDRATAK™
 - AQUAFLOW-PLUS®
 - FUTURE-LINE®
 - X-STREAM®
 - AQUAPOWER™
 - X-STREAM® PLUS



Patents : US 9,539,449; Canada 2,753,087; South Africa 2011/06223; UK 2,480,968. Other patents pending



HOW TO SPECIFY

MERTEX

WAYOUT®

- The female coupling must have reflective arrows that are visible from any position
- The reflective arrows must be engraved into and below the surface of the coupling, to resist abrasion
- The arrows must point in the direction of the water source
- The couplings must be available in sizes from 1 to 3 inch diameter (25mm to 76mm)
- Sizes 1.5 to 3 inch diameter (38mm to 76mm) must have a recessed area to facilitate color labels, bar code labels, identification stamping, etc.
- The couplings must conform to NFPA standards
- The fire hose connection or fitting shall be permanently and legibly marked on the outside surface of the product, with the manufacturer's name or trademark
- The thread size and designation (e.g. 1 1/2" / 38 mm NH) shall have a minimum letter height of 0.10 in, (0.255 mm)
- The fire hose connection or fitting shall be permanently and legibly marked on the outside surface of the product, with the country of manufacturing origin
- The couplings must be hard anodized to MIL spec 8625 type III. The anodized treatment must be resistant to chipping & deterioration due to abrasion
- The coupling must be available in gold and standard anodizing
- The couplings must be manufactured in North America and be NAFTA compliant
- The coupling must have a Two Year All Hazards Warranty and 10 years warranty against manufacturing defects

Important : Fire departments must observe the standard connectivity of the female end to the water source